



☞ incorrect Kordon TB installation. Refer kd 001 and product design principle

1.



4.

☞ if tiling is to extend to slab edge Kordon TB is installed as shown - secured with gal hoop-iron/strapping.



2.



5.

☞ renderlok secured to masonry with approved concrete nails. - (15mm length preferred)



3.

☞ close up of 5.



6.

☞ renderlok secured to horizontal & vertical to accommodate tiling specification

KORDON TERMITE BARRIER

Subject

sill tile details

Sheet No.

kd 048c